

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Saad Benchakroun	01.12.2021	11:07:11	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	23.69 °C
Aerosol	Pressurized air	rel. humidity	2.58 %

Mask information

Mask ID	13868_20211201_110711
Mask lot	211201-F-L3-2-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	30.05 l/min	35.27 Pa	70.00 Pa	✔ pass
Inhalation 2	94.82 l/min	108.25 Pa	240.00 Pa	✔ pass
Exhalation	160.02 l/min	189.87 Pa	300.00 Pa	✔ pass



Calibration valid until 03.09.2022

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Saad Benchakroun	01.12.2021	11:11:06	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.84 l/min
Generator air	2.68 l/min

Test conditions	
Temperature	23.69 °C
rel. humidity	2.25 %
Mass concentration	20.96 mg/m ³

Mask information


Mask ID	13868_20211201_111106
Mask lot	211201-F-L3-2-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	3.65 %	30.00 %	✓ pass
P_m	0.79 %		
P_Ph_45°	0.74 %	6.00 %	✓ pass

Distributions



Calibration valid until 03.09.2022