

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Saad Benchakroun	28.12.2021	10:29:45	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	24.43 °C
Aerosol	Pressurized air	rel. humidity	2.80 %

Mask information

Mask ID	13868_20211228_102945
Mask lot	211223-F-L4-2-M2a-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	30.03 l/min	33.48 Pa	70.00 Pa	✔ pass
Inhalation 2	94.80 l/min	99.28 Pa	240.00 Pa	✔ pass
Exhalation	160.04 l/min	174.36 Pa	300.00 Pa	✔ pass



Calibration valid until 03.09.2022

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Saad Benchakroun	28.12.2021	10:34:23	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.98 l/min
Generator air	2.63 l/min

Test conditions	
Temperature	24.46 °C
rel. humidity	2.34 %
Mass concentration	20.66 mg/m ³

Mask information


Mask ID	13868_20211228_103423
Mask lot	211223-F-L4-2-M2a-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	1.78 %	6.00 %	✓ pass
P_m	0.15 %		
P_Ph_45°	0.18 %	6.00 %	✓ pass

Distributions



Calibration valid until 03.09.2022