

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Demet	24.03.2022	12:32:44	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	20.45 °C
Aerosol	Pressurized air	rel. humidity	3.34 %

Mask information

Mask ID	13868_20220324_123244
Mask lot	220323-F-L4-2-M2a-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	29.97 l/min	30.56 Pa	70.00 Pa	✔ pass
Inhalation 2	94.70 l/min	94.96 Pa	240.00 Pa	✔ pass
Exhalation	159.91 l/min	160.79 Pa	300.00 Pa	✔ pass



Calibration valid until 03.09.2022

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Demet	24.03.2022	12:37:21	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.97 l/min
Generator air	2.63 l/min

Test conditions	
Temperature	20.56 °C
rel. humidity	2.83 %
Mass concentration	18.35 mg/m ³

Mask information


Mask ID	13868_20220324_123721
Mask lot	220323-F-L4-2-M2a-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	5.63 %	20.00 %	✓ pass
P_m	1.98 %		
P_Ph_45°	2.23 %	6.00 %	✓ pass

Distributions



Calibration valid until 03.09.2022