

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Saad Benchakroun	04.04.2022	09:10:46	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	16.07 °C
Aerosol	Pressurized air	rel. humidity	4.33 %

Mask information

Mask ID	13868_20220404_091046
Mask lot	220331-F-L4-2-M2a-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	29.99 l/min	38.61 Pa	70.00 Pa	✔ pass
Inhalation 2	94.79 l/min	103.88 Pa	240.00 Pa	✔ pass
Exhalation	159.90 l/min	173.91 Pa	300.00 Pa	✔ pass



Calibration valid until 03.09.2022

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Saad Benchakroun	04.04.2022	09:14:45	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.90 l/min
Generator air	2.84 l/min

Test conditions	
Temperature	16.16 °C
rel. humidity	4.00 %
Mass concentration	16.43 mg/m³

Mask information


Mask ID	13868_20220404_091445
Mask lot	220331-F-L4-2-M2a-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	0.91 %	20.00 %	✓ pass
P_m	0.33 %		
P_Ph_45°	0.45 %	6.00 %	✓ pass

Distributions



Calibration valid until 03.09.2022