

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Saad	09.05.2022	09:15:25	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	20.46 °C
Aerosol	Pressurized air	rel. humidity	4.79 %

Mask information

Mask ID	13868_20220509_091525
Mask lot	220505-F-L3-2-M2a-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	30.04 l/min	38.27 Pa	70.00 Pa	✔ pass
Inhalation 2	94.84 l/min	106.49 Pa	240.00 Pa	✔ pass
Exhalation	159.92 l/min	179.50 Pa	300.00 Pa	✔ pass



Calibration valid until 03.09.2022

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Saad	09.05.2022	09:19:36	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.93 l/min
Generator air	2.75 l/min

Test conditions	
Temperature	20.52 °C
rel. humidity	4.90 %
Mass concentration	19.21 mg/m ³

Mask information


Mask ID	13868_20220509_091936
Mask lot	220505-F-L3-2-M2a-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	2.04 %	20.00 %	✔ pass
P_m	0.65 %		
P_Ph_45°	0.28 %	6.00 %	✔ pass

Distributions



Calibration valid until 03.09.2022