

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Saad Benchakroun	26.04.2022	15:38:35	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	23.20 °C
Aerosol	Pressurized air	rel. humidity	3.51 %

Mask information

Mask ID	13868_20220426_153835
Mask lot	220425-S-L5-2-MLK-SW-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	30.05 l/min	35.18 Pa	70.00 Pa	✔ pass
Inhalation 2	94.75 l/min	111.06 Pa	240.00 Pa	✔ pass
Exhalation	159.95 l/min	182.63 Pa	300.00 Pa	✔ pass



Calibration valid until 03.09.2022

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Saad Benchakroun	26.04.2022	15:48:56	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.94 l/min
Generator air	2.59 l/min

Test conditions	
Temperature	23.20 °C
rel. humidity	2.74 %
Mass concentration	22.13 mg/m ³

Mask information


Mask ID	13868_20220426_154856
Mask lot	220425-S-L5-2-MLK-SW-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	2.66 %	20.00 %	✔ pass
P_m	0.31 %		
P_Ph_45°	0.29 %	6.00 %	✔ pass

Distributions



Calibration valid until 03.09.2022