

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Dustin	12.09.2022	14:50:27	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.93 l/min
Generator air	2.53 l/min

Test conditions	
Temperature	24.14 °C
rel. humidity	3.32 %
Mass concentration	18.53 mg/m ³

Mask information


Mask ID	13868_20220912_145027
Mask lot	220912-F-L5-2-MLK-A-IN_DM
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	5.03 %	20.00 %	✓ pass
P_m	0.16 %		
P_Ph_45°	0.39 %	6.00 %	✓ pass

Distributions



Calibration expired since 03.09.2022

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Dustin	12.09.2022	14:46:27	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	24.00 °C
Aerosol	Pressurized air	rel. humidity	2.70 %

Mask information

Mask ID	13868_20220912_144627
Mask lot	220912-F-L5-2-MLK-A-IN_DM
Mask type	DMASKE / Chargentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	30.20 l/min	42.42 Pa	70.00 Pa	✔ pass
Inhalation 2	94.91 l/min	148.97 Pa	240.00 Pa	✔ pass
Exhalation	160.03 l/min	288.48 Pa	300.00 Pa	✔ pass



Calibration expired since 03.09.2022