

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Dustin	22.09.2022	09:20:59	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.82 l/min
Generator air	2.69 l/min

Test conditions	
Temperature	22.10 °C
rel. humidity	4.23 %
Mass concentration	20.26 mg/m³

Mask information


Mask ID	13868_20220922_092059
Mask lot	220921-S-L5-2-MLK-A-IN_DM
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	3.76 %	20.00 %	✔ pass
P_m	0.11 %		
P_Ph_45°	0.26 %	6.00 %	✔ pass

Distributions



Calibration expired since 03.09.2022

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Dustin	22.09.2022	09:16:29	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	21.95 °C
Aerosol	Pressurized air	rel. humidity	3.83 %

Mask information

Mask ID	13868_20220922_091629
Mask lot	220921-S-L5-2-MLK-A-IN_DM
Mask type	DMASKE / Chagentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	29.92 l/min	37.22 Pa	70.00 Pa	✔ pass
Inhalation 2	94.82 l/min	108.06 Pa	240.00 Pa	✔ pass
Exhalation	159.89 l/min	190.51 Pa	300.00 Pa	✔ pass



Calibration expired since 03.09.2022