

Test report - PMFT 1000 - Oil penetration

Operator	Date	Time	Vesion
Hikmet	07.12.2022	13:30:59	1.11.1.0

Basic information

Operation parameter	
Script	Effizienz Test (Öl)
Aerosol	Oil
Main air	94.96 l/min
Generator air	2.75 l/min

Test conditions	
Temperature	19.98 °C
rel. humidity	3.42 %
Mass concentration	19.92 mg/m³

Mask information


Mask ID	13868_20221207_133059
Mask lot	221206-S-L5-MLK-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Calculation of the penetration is based on the following parameters: $X_g = 0.29 \mu\text{m}$, $\text{Sigma} = 1.85$

Penetration	Measurement	Upper limit	Result
P_SARS_CoV-2 (0.15 μm)	2.18 %	20.00 %	✓ pass
P_m	0.05 %		
P_Ph_45°	0.09 %	6.00 %	✓ pass

Distributions



Calibration expired since 03.09.2022

Test report - PMFT 1000 - Breath resistance / Valve test

Operator	Date	Time	Vesion
Hikmet	07.12.2022	13:24:37	1.11.1.0

Basic information

Operation parameter		Test conditions	
Script	Atemwiderstand	Temperature	19.95 °C
Aerosol	Pressurized air	rel. humidity	3.82 %

Mask information

Mask ID	13868_20221207_132437
Mask lot	221206-S-L5-MLK-A-IN
Mask type	DMASKE / Chargentest / FFP 2

Result

Description	Main air	Differential pressure	Upper limit	Result
Inhalation 1	30.15 l/min	38.73 Pa	70.00 Pa	✓ pass
Inhalation 2	94.70 l/min	120.56 Pa	240.00 Pa	✓ pass
Exhalation	159.85 l/min	213.95 Pa	300.00 Pa	✓ pass



Calibration expired since 03.09.2022